

**This information relates to Assessments conducted in
Victoria ONLY for High Risk Licensing**

**and is an addendum to the on-line
Assessment Instruments found on the
WorkCover NSW website**

WORKING NEAR OVERHEAD POWERLINES

VIC requirements (refer Question 23 of the Assessment Instrument)

3 metres from domestic powerlines
with a 'qualified spotter' and 8 metres
from high voltage transmission
lines with a 'qualified spotter'

OR

6.4 metres from domestic powerlines
and 10 metres from high voltage
transmission lines.